

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 1994/विविध-35/131

Date 25.08.2026

It is certified that an inspection team headed by EXECUTIVE ENGINEER from DIVISION OFFICE U.P JAL NIGAM (RURAL) DISTRICT-MAHARAJGANJ inspected the **MOTHER MARIAM GLOBAL SCHOOL, Kharharwa, Kolhui, District- Maharajganj** (Name & Address of the School) on 12.08.2026 (date of inspection) and on the basis of Water Test Report (Attached) bearing URL No. TC-16954/26/0000000801F Dated 14.08.2026 of District Level Water Analysis Laboratory (NABL Lab) Certificate that the **MOTHER MARIAM GLOBAL SCHOOL** (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/UT Govt.

The certificate is valid till 14.08.2026 to 14.02.2027



**Executive Engineer
Division Office
U.P. Jal Nigar (Rural)
District-Maharajganj**

To,

**MOTHER MARIAM GLOBAL SCHOOL,
Kharharwa, Kolhui,
District- Maharajganj.**

Note-The Certificate is to be issued by authorized officer / NABL Lab/Local bodies

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Date .08.2026

It is certified that an inspection team headed by EXECUTIVE ENGINEER from DIVISION OFFICE U.P JAL NIGAM (RURAL) DISTRICT-MAHARAJGANJ inspected the **MOTHER MARIAM GLOBAL SCHOOL, Kharharwa, Kolhui, District- Maharajganj** (Name & Address of the School) on 12.08.2026 (date of inspection) and on the basis of Water Test Report (Attached) bearing URL No. TC-16954/26/0000000801F Dated 14.08.2026 of District Level Water Analysis Laboratory (NABL Lab) Certificate that the **MOTHER MARIAM GLOBAL SCHOOL** (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/UT Govt.

The certificate is valid till 14.08.2026 to 14.02.2027


Executive Engineer
Division Office
U.P. Jal Nigar (Rural)
District-Maharajganj

To,

**MOTHER MARIAM GLOBAL SCHOOL,
Kharharwa, Kolhui,
District- Maharajganj.**

Note-The Certificate is to be issued by authorized officer / NABL Lab/Local bodies



**District Level Water Analysis Laboratory,
U.P. Jal Nigam(Rural), Maharajganj**
Rampur Satbhariya Water Supply Campus, Gorakhpur Road,
District-Maharajganj-273303



TC-16954

Analysis Report

URL No. TC-16954/26/0000000801F

Date 14.08.2026

Page No. 1/2

Customer Name - Principal

Address - MOTHER MARIAM GLOBAL SCHOOL, Kharharwa, Kolhui, District- Maharajganj

Reference Letter No. - N/A

Basic Details of sample**District- Maharajganj**

Gram Panchayat/ Nagar	Kharharwa, Kolhui	Village/Nagar	Kharharwa, Kolhui
		Latitude	27.309498
		Longitude	83.319914
Habitation	Kharharwa, Kolhui	Location	MOTHER MARIAM GLOBAL SCHOOL, Kharharwa, Kolhui, District- Maharajganj
Water Source	R.O.	Date of S.C.	11.08.2026
Quantity of Sample	1500ml	Sample Collector	By Sampler
Receiving Date	11.08.2026	Analysis Completion Date-	14.08.2026
Sample Receive	Sampler		
Analysis Start Date	11.08.2026		
Temperature - 25 +-C		Relative Humidity - 50+-15%	

Technical Data of Analysis

S.No.	Analysed parameters (Unit of Measurement)	Observed Value	Unit	Specified Values as per BIS		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	Turbidity	1.69	NTU	1.00	5.00	IS 3025 (Part 10) : 2023
2	TDS	92.00	mg/L	500.00	2000.00	IS 3025 (Part 16) : 2023
3	pH	7.69	-	6.5 - 8.5	No relaxation	IS 3025 (Part 11) : 2022
4	Total Hardness	86.00	mg/L	200.00	600.00	IS 3025 (Part 21) : 2019
5	Total Alkalinity	102.00	mg/L	200.00	600.00	IS 3025 (Part 23) : 2023
6	Chloride as Cl	22.00	mg/L	250.00	1000.00	IS 3025 (Part 32) : 2019
7	Calcium	24.48	mg/L	75.00	200.00	IS 3025 (Part 40) : 2019
8	Magnesium	6.24	mg/L	30.00	100.00	IS 3025 (Part 46) : 2019
9	Colour	5.00	Hazen	5.00	15.00	IS 3025 (Part 4) : 2021
10	Sulphate	26.49	mg/L	200.00	400.00	APHA24rd Edition-4500-SO4 Method E (Turbidimetric Method)
11	Nitrate	1.79	mg/L	45.00	No relaxation	APHA24rd Edition-4500-NO3 Method B (UV Screening Method)
12	Iron	0.000	mg/L	1.00	No relaxation	APHA24rd Edition-4500-Fe Method B (Phenanthroline- Method)
13	Arsenic	0.00	mg/L	0.01	No relaxation	APHA24rd Edition-4500-As Method B (Silverdiethyldithiocarbamate- Method)
14	Fluoride	0.000	mg/L	1.00	1.50	APHA24rd Edition-4500-F Method C (Electrode Method)

Note:-

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of tests reports unless other wise specified.

PK
Prepared By

Anand Agushaw
Review By

Radheyshyam Rawat
Quality Manager

Authorized Signatory

Mob.No. 8858396541

Lab E-Mail ID :- ritikalalmrj@gmail.com

End of Test Report

UPIN-MRJ



District Level Water Analysis Laboratory,
U.P. Jal Nigam(Rural), Maharajganj
 Rampur Satbhariya Water Supply Campus, Gorakhpur Road,
 District-Maharajganj-273303

Date 14.08.2026

Page No. 1/2

Technical Data of Analysis

S.No.	Analysed parameters (Unit of Measurement)	Observed Value	Unit	Specified Values as per BIS		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	Conductivity	184.00	mS/cm	NA	NA	IS 3025 (Part 14)
2	E-Coli (Bacteria)	0.00	CFU	Nil	Nil	IS 15181:2016

- Note:-**
1. This Certificate refers only to the particular sample(s) submitted for testing.
 2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
 3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
 4. Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of tests reports unless other wise specified.

Prepared By

Review By

(Radheyshyam Rawat)
Quality Manager
Authorized Signatory
Mob.No. 8858396541

Lab E-Mail ID :- ritikalalmrj@gmail.com

End of Test Report